






180° Connector Suspended Optional Please read note* on using connectors!!!














- A) Surface Mounted

 1. Remove End Cap (Pull)
 Unscrew and slide out bracket
 2. Remove ceiling mounting profile
 3. Pull wiring through ceiling mounting profile
 Fix ceiling mounting profile to ceiling
 4. Connect wiring to terminal on the inside of the main profile
 5. Snap main profile back onto the ceiling profile
 6. Slide bracket into ceiling profile
 Fix bracket with screw
 7. Place end cap back

B) Standard Suspension Bracket

- B) Standard Suspension Bracket
 1. Disassemble ceiling fixation
 2. Fix ceiling fixation to ceiling using screws
 3. Pull steel wire through bottom part of ceiling fixation
 4. Reassemble ceiling fixation
 5. Remove end caps
 6. Assemble suspension bracket
 7. Place suspension bracket into profile
 8. Place end caps back
 9. Insert suspension wire into wire gripper
- 8.Place end caps back
 9.Insert suspension wire into wire gripper
 Adjust height and make sure profile is leveled
 10.Make power connection (see page connection boxes)

- C) Invisible Suspension

 1. Disassemble ceiling fixation

 2. Fix ceiling fixation to ceiling using screws

 3. Remove end caps

2. Fix ceiling fixation to ceiling using screws
3. Remove end caps
4. Remove end caps
4. Remove top cover
Remove indirect lighting profile (only for up/down)
5. Pull steel suspension wire through bottom part of ceiling fixation
6. Pull steel suspension wire through top cover
Pull steel suspension wire through indirect lighting profile (only for up/down)
Insert suspension wire into wire gripper (A)
Mount profile to ceiling by screwing bottom part of ceiling fixation to top part (B)
Adjust height and make sure profile is leveled (C)
7. Snap indirect lighting profile back into outer profile (only for up/down)
Make sure cables are not pinched between the 2 profiles
Place top cover back
Place end cap back
8 Make power connection (see page connection boxes)

Attention!! ATTENTION!!

ATTENTION!!

ATTENTION!!

ATTENTION THE TOP WHITEN W

- 90°/180° Connector Suspended

 1.Place connector in slots (see marked locations)

 2.Make power connection between profiles
 Fix connector bracket in first profile part
 Slide profile parts against each other
 Fix connector bracket in second profile
 3 Place magnetic corpus piece into corpus
- Place magnetic corner piece into corner (only for 90° connector with UGR grid)
- (only for 90° connector with UGR gnd)
 90°/180° Connector Ceiling Mounted
 1. Place first part of profile against ceiling
 Fix brackets on ends
 2. Fix ceiling part of second profile.
 Connect wiring.
 Slide second profile onto brackets.
 Snap profile on to ceiling part.
 Fix bracket on profile end.

*NOTE ON USING CONNECTORS (90°/180°)
For prevention of light leakage caused by the small gap on the connection of 2 profiles please place tape over gaps. See page "Light leakage prevention"

This document subject to change.
Please visit www.doxis.be for the latest updates